

Card Access Control Specifications

1.0 Qualifications

- 1.01 Vendors must be pre-qualified for card access on the SHSU campus. No 3rd party installations permitted.

2.0 General Requirements and Notes

- 2.00 SHSU requires that all exterior doors for public access (including each operable leaf) have active electronic card access monitoring and scheduling for door lock/unlock. Monitoring to include ALL exterior openings to include, operable windows, balcony doors, mechanical room doors, roll up doors, roof access doors, and roof access/hatches. No Exceptions.
- 2.01 Access Services or Residents Life reserve the right to approve or reject final design and/or scope of work for access control on any structures new or existing.

3.0 Base Specifications

- 3.01 The system must fully and completely integrate with the most current version of CCURE 9000 door access system purchased from Software House/Tyco Electronic Product Group.

4.0 Standardized Hardware

- 4.00 The following hardware is specified hardware for access control integrations. No substitutions are allowed.

- 4.01 **Controllers**
iSTAR Intelligent Network Controllers

ISTAR002 iSTAR Edge – 2-reader controller

ISTAR004 iSTAR Edge – 4-reader controller

ISTAR ULTRA – 16 READER CONTROLLER

- 4.02 **Readers**

Schlage MTM S15 Card Reader/ Multi-tech and mag reader track 3

RESI LIFE REQUIRES = SOFTWARE HOUSE RM4/RM1 READERS

- 4.03 **Exit Devices (Mechanical)**
Von Duprin 98/99 Series OEL
Not used in Resi Life Buildings

- 4.04 **Electric Strikes**

Von Duprin Series 6000 24 Volt

HES 1006 Strike

HES 9600 RIM Strike or HES 9500 RIM for fire rated applications

4.05 **Electric Power Transfer**

Von Duprin

EPT-10 or EPT-10con

Armored cable door loops – used on pivot hinge doors in place of GVUX power transfer.

Alarm Lock AL271

Keedex K-DLA12

4.06 **Power Supplies and Batteries**

Altronix AL600 Series Power Supplies

Altronix Batteries

Base Electronics LVPC201144-24 - 8 Door Power Distribution Enclosure with Aux Power Output for auxillary door components (REX motion detector, sounders, etc.)

Base Electronics LVPC201181-24 - 16 Door Power Distribution Enclosure with Aux Power Output for auxillary door components (REX motion detector, sounders, etc.)

Von Duprin PS914 to include 900 battery back-up kit and an additional 900 2RS 2 relay EL panic device control board.

4.07 **Relays**

Altronix Relay

Altronix 6062 – Time delay relay (for ADA doors.)

IDEC

IDEC RHU1B and RHU2B Relays (in Base Power Distribution Enclosures)

4.09 **Request to Exit (REX) Request to exit**

Rex Switches are preferred of motion detectors. Motion detectors to be used as last resort.

Detection Systems : *BOSCH* DS 150i Request to Exit Motion Detector

No Rex switches in Residence Halls. Use only motion detectors.

4.10 **Cabling: Composite Cabling**

658AFJ Belden or equivalent

4.11 **Personality Module and Housing**

RM4 Reader Module

4.12 **Door Switches**

